

896435

County Becker
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date
Update Date 04/30/2026
Received Date 02/03/2026

Well Name MCKINNON,	Township 138	Range 41	Dir W	Section 5	Subsection CDD	Well Depth 127 ft.	Depth Completed 127 ft.	Date Well Completed 12/02/2025		
Elevation	Elev. Method					Drill Method Non-specified Rotary	Drill Fluid Bentonite			
Address						Use domestic	Status Active			
Contact 1977 67TH AV S FARGO ND 58104						Well Hydrofractured? Yes ☐ No ☒ From To				
Well 15238 MUNSON DR E DETROIT LAKES MN 56501						Casing Type Single casing Joint				
Stratigraphy Information						Drive Shoe? Yes ☐ No ☒ Above/Below				
Geological Material		From	To (ft.)	Color	Hardness	Casing Diameter Weight Hole Diameter				
TOP SOIL		0	1	BLACK	SOFT	4 in. To 119 ft. 1 lbs./ft. 6.7 in. To 127 ft.				
GRAVEL		1	30	BROWN	SOFT					
CLAY		30	117	BLUE	SOFT					
SAND		117	127	GRAY	SOFT					
Open Hole						From	ft.	To	ft.	
Screen? ☒						Type stainless	Make JOHNSON			
Diameter						Slot/Gauze	Length	Set		
4 in.						12	8 ft.	119 ft.	127 ft.	
Static Water Level										
26 ft.						land surface	Measure	11/03/2025		
Pumping Level (below land surface)										
118 ft.						1 hrs.	Pumping at	60	g.p.m.	
Wellhead Completion										
Pitless adapter manufacturer						MONITOR	Model	SNAPPY		
☐ Casing Protection						☒ 12 in. above grade				
☐ At-grade (Environmental Wells and Borings ONLY)										
Grouting Information						Well Grouted?	☒ Yes	☐ No	☐ Not Specified	
Material						Amount	From	To		
other						7 Sacks	ft.	50	ft.	
Nearest Known Source of Contamination										
54 feet						East Direction	Sewer Type			
Well disinfected upon completion?						☒ Yes	☐ No			
Pump ☐ Not Installed						Date Installed	12/02/2025			
Manufacturer's name						PENTEK				
Model Number						S10P4IP102	HP	1	Volt 230	
Length of drop pipe						0 ft	Capacity	20	g.p. Typ	
Abandoned										
Does property have any not in use and not sealed well(s)?						☐ Yes	☒ No			
Variance										
Was a variance granted from the MDH for this well?						☐ Yes	☒ No			
Miscellaneous										
First Bedrock						Aquifer				
Last Strat						Depth to Bedrock				ft
Located by										
Locate Method										
System						UTM - NAD83, Zone 15, Meters	X	Y		
Unique Number Verification						Input Date				
Angled Drill Hole										
Well Contractor										
Elsner Well Drilling, Inc.						1374	MONROE, S.			
Licensee Business						Lic. or Reg. No.	Name of Driller			