

896664

County Sherburne
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 05/05/2026
Update Date 05/05/2026
Received Date 03/02/2026

Well Name CHOICE HOMES	Township 35	Range 26	Dir Section W 34	Subsection CAB	Well Depth 115 ft.	Depth Completed 115 ft.	Date Well Completed 01/06/2026
Elevation	Elev. Method				Drill Method Non-specified Rotary	Drill Fluid	Other
Address					Use domestic	Status Active	
Well 11772 280TH AV NW ZIMMERMAN MN 55378					Well Hydrofractured? Yes ☐ No ☒ From To		
Contact 22465 MARBLE ST NW ELK RIVER MN 55330					Casing Type Single casing Joint Glued		
Stratigraphy Information					Drive Shoe? Yes ☐ No ☒ Above/Below		
Geological Material From To (ft.) Color Hardness					Casing Diameter Weight Hole Diameter		
SAND 0 32 BROWN SOFT					4 in. To 102 ft. 2.1 lbs./ft. 8 in. To 30 ft.		
CLAY 32 36 GRAY SOFT					6.5 in. To 115 ft.		
SAND 36 47 BROWN SOFT							
CLAY 47 98 GRAY SFT-MED							
SAND 98 115 GRAY SOFT							
					Open Hole From ft. To ft.		
					Screen? ☒ Type plastic Make MONOFLEX		
					Diameter Slot/Gauze Length Set		
					2 in. 15 14 ft. 102 ft. 115 ft.		
					4 in. 15 14 ft. 102 ft. 115 ft.		
					Static Water Level		
					65 ft. land surface Measure 12/16/2025		
					Pumping Level (below land surface)		
					ft. 1 hrs. Pumping at 20 g.p.m.		
					Wellhead Completion		
					Pitless adapter manufacturer AQUA SEAL Model T4-1		
					☐ Casing Protection ☒ 12 in. above grade		
					☐ At-grade (Environmental Wells and Borings ONLY)		
					Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified		
					Material Amount From To		
					cuttings 60 ft. 102 ft.		
					bentonite 5 Sacks ft. 60 ft.		
					Nearest Known Source of Contamination		
					50 feet West Direction Sewer Type		
					Well disinfected upon completion? ☒ Yes ☐ No		
					Pump ☐ Not Installed Date Installed 01/06/2026		
					Manufacturer's name GOULDS		
					Model Number 10CS05 HP 0.5 Volt 230		
					Length of drop pipe 80 ft Capacity 10 g.p. Typ Submersible		
					Abandoned		
					Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No		
					Variance		
					Was a variance granted from the MDH for this well? ☐ Yes ☒ No		
					Miscellaneous		
					First Bedrock Aquifer		
					Last Strat Depth to Bedrock ft		
					Located by		
					Locate Method		
					System UTM - NAD83, Zone 15, Meters X Y		
					Unique Number Verification Input Date		
					Angled Drill Hole		
					Well Contractor		
					Able Well, Inc. 1377 THOMPSON, S		
					Licensee Business Lic. or Reg. No. Name of Driller		