

896710

County Swift
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 05/05/2026
Update Date 05/05/2026
Received Date 12/22/2025

Well Name THORSON,	Township 121	Range 37	Dir W	Section 16	Subsection BAB	Well Depth 96 ft.	Depth Completed 94 ft.	Date Well Completed 12/11/2025
Elevation	Elev. Method					Drill Method Non-specified Rotary	Drill Fluid Bentonite	
Address						Use domestic	Status Active	
C/W 1440 20TH ST SE MURDOCK MN 56271						Well Hydrofractured? Yes ☐ No ☒	From	To
Stratigraphy Information						Casing Type Single casing	Joint	
						Drive Shoe? Yes ☐ No ☒	Above/Below	
Geological Material						Casing Diameter	Weight	Hole Diameter
TOP SOIL						5 in. To	84 ft. lbs./ft.	8.7 in. To 84 ft.
CLAY								
SAND/ GRAVEL								
CLAY								
CLAY								
CLAY W/ FINE SAND								
CLAY								
SAND/ SMALL								
COBBLE/ CLAY								
						Open Hole	From	ft. To
						Screen? ☒	Type plastic	Make JOHNSON
						Diameter	Slot/Gauze	Length
						5 in.	15	5 ft. 84 ft. 94 ft.
						5 in.	10	5 ft. 84 ft. 94 ft.
						Static Water Level		
						35.7 ft.	land surface	Measure 12/08/2025
						Pumping Level (below land surface)		
						80 ft.	2 hrs.	Pumping at 20 g.p.m.
						Wellhead Completion		
						Pitless adapter manufacturer	MERRILL	Model MCK
						☐ Casing Protection	☐ 12 in. above grade	
						☐ At-grade (Environmental Wells and Borings ONLY)		
						Grouting Information	Well Grouted?	☒ Yes ☐ No ☐ Not Specified
						Material	Amount	From To
						bentonite	8 Sacks	ft. 75 ft.
						Nearest Known Source of Contamination		
						65 feet	East Direction	Septic tank/drain field Type
						Well disinfected upon completion?	☒ Yes ☐ No	
						Pump ☐ Not Installed	Date Installed	12/09/2025
						Manufacturer's name	STA-RITE	
						Model Number	S10P4JP052	HP 0.5 Volt 230
						Length of drop pipe	80 ft	Capacity 10 g.p. Typ Submersible
						Abandoned		
						Does property have any not in use and not sealed well(s)?	☐ Yes ☒ No	
						Variance		
						Was a variance granted from the MDH for this well?	☐ Yes ☒ No	
						Miscellaneous		
						First Bedrock	Aquifer	
						Last Strat	Depth to Bedrock	ft
						Located by		
						Locate Method		
						System	UTM - NAD83, Zone 15, Meters	X Y
						Unique Number Verification		Input Date
						Angled Drill Hole		
						Well Contractor		
						Thein Well Co., Inc.	1337	THEIN, A
						Licensee Business	Lic. or Reg. No.	Name of Driller