

897023

County Aitkin
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 01/26/2026
Update Date 01/26/2026
Received Date 12/15/2025

Well Name LORENCE,					Township 43	Range 22	Dir Section W 26	Subsection ABC	Well Depth 122 ft.				Depth Completed 122 ft.				Date Well Completed 12/08/2025			
Elevation					Elev. Method					Drill Method Multiple methods used				Drill Fluid						
Address									Use domestic				Status Active							
Well 11361 117TH ST FINLAYSON MN 55735									Well Hydrofractured? Yes ☐ No ☒ From To											
Contact 5411 NORMANDY CT WHITE BEAR LAKE MN 55110									Casing Type Single casing				Joint Welded							
Stratigraphy Information									Drive Shoe? Yes ☒ No ☐ Above/Below											
Geological Material		From	To (ft.)	Color	Hardness				Casing Diameter 6 in. To 120 ft. 19 lbs./ft.				Hole Diameter 6 in. To 122 ft.							
SAND/ CLAY		0	20																	
ROCKY SILT CLAY		20	80																	
BOULDERS		80	120																	
GRAVEL		120	122																	
									Open Hole From 120 ft. To 122 ft.											
									Screen? ☐ Type Make											
Static Water Level 3 ft. land surface Measure 12/08/2025																				
Pumping Level (below land surface) 80 ft. 1 hrs. Pumping at 10 g.p.m.																				
Wellhead Completion Pitless adapter manufacturer SNAPPY Model 6X1 ☐ Casing Protection ☒ 12 in. above grade ☐ At-grade (Environmental Wells and Borings ONLY)																				
Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified Material Amount From To driven casing seal ft. 120 ft.																				
Nearest Known Source of Contamination 70 feet East Direction Septic tank/drain field Type Well disinfected upon completion? ☐ Yes ☐ No																				
Pump ☐ Not Installed Date Installed 12/08/2025 Manufacturer's name GRUNDFOS Model Number HP 0.75 Volt 220 Length of drop pipe 100 ft Capacity 10 g.p. Typ Submersible																				
Abandoned Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No																				
Variance Was a variance granted from the MDH for this well? ☐ Yes ☒ No																				
Miscellaneous First Bedrock Aquifer Last Strat Depth to Bedrock ft Located by Locate Method System UTM - NAD83, Zone 15, Meters X Y Unique Number Verification Input Date																				
Angled Drill Hole																				
Well Contractor Bob Kent Well Drilling 1886 KENT, B Licensee Business Lic. or Reg. No. Name of Driller																				
Remarks																				