

897213

County Hubbard
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 02/13/2026
Update Date 02/13/2026
Received Date 10/09/2025

Well Name TORKELSON,	Township 139	Range 33	Dir Section W 11	Subsection BBB	Well Depth 60 ft.	Depth Completed 60 ft.	Date Well Completed 10/01/2025
Elevation	Elev. Method				Drill Method Non-specified Rotary	Drill Fluid	Other
Address					Use domestic	Status Active	
Contact 15616 CHOKECHERRY DR NEVIS MN 56467					Well Hydrofractured? Yes ☐ No ☒ From To		
Well 15614 CHOKECHERRY DR NEVIS MN 56467					Casing Type Single casing Joint		
Stratigraphy Information					Drive Shoe? Yes ☐ No ☒ Above/Below		
Geological Material		From	To (ft.)	Color	Hardness	Casing Diameter Weight Hole Diameter	
SAND		0	60	BROWN	SOFT	4 in. To 52 ft. lbs./ft. 6.7 in. To 60 ft.	
					Open Hole From ft. To ft.		
					Screen? ☒ Type stainless Make JOHNSON		
					Diameter Slot/Gauze Length Set		
					3 in. 12 8 ft. 52 ft. 60 ft.		
					Static Water Level		
					50 ft. land surface Measure 10/01/2025		
					Pumping Level (below land surface)		
					52 ft. 2 hrs. Pumping at 10 g.p.m.		
					Wellhead Completion		
					Pitless adapter manufacturer MONITOR Model SNAPPY 4X1		
					☐ Casing Protection ☒ 12 in. above grade		
					☐ At-grade (Environmental Wells and Borings ONLY)		
					Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified		
					Material Amount From To		
					other 4 Sacks ft. 50 ft.		
					Nearest Known Source of Contamination		
					110 feet Northeas Direction Septic tank/drain field Type		
					Well disinfected upon completion? ☒ Yes ☐ No		
					Pump ☐ Not Installed Date Installed 10/01/2025		
					Manufacturer's name GRUNDFOS		
					Model Number SQ HP 0.5 Volt 115		
					Length of drop pipe 45 ft Capacity 10 g.p. Typ Submersible		
					Abandoned		
					Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No		
					Variance		
					Was a variance granted from the MDH for this well? ☐ Yes ☒ No		
					Miscellaneous		
					First Bedrock Aquifer		
					Last Strat Depth to Bedrock ft		
					Located by		
					Locate Method		
					System UTM - NAD83, Zone 15, Meters X Y		
					Unique Number Verification Input Date		
					Angled Drill Hole		
					Well Contractor		
					Doug's Water Wells 6217 TORKELSON, P		
					Licensee Business Lic. or Reg. No. Name of Driller		

Remarks
TORKELSON WELL SERVICE JOB
6" OF DRAWDOWN W/ PUMP OPEN DIS