

897214

County Hubbard
Quad Park Rapids
Quad ID 256A

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 01/06/2026
Update Date 02/16/2026
Received Date 10/14/2025

Well Name CHEYENNE					Township 140	Range 34	Dir W	Section 7	Subsection CAAABA	Well Depth 84 ft.		Depth Completed 84 ft.		Date Well Completed 09/25/2025			
Elevation					Elev. Method					Drill Method Non-specified Rotary		Drill Fluid Other					
Address										Use domestic		Status Active					
Well 16435 204TH ST PARK RAPIDS MN 56470										Well Hydrofractured? Yes ☐ No ☒ From To							
Contact 20413 HUNTER RD PARK RAPIDS MN 56470										Casing Type Single casing		Joint					
Stratigraphy Information										Drive Shoe? Yes ☐ No ☒		Above/Below					
Geological Material		From	To (ft.)	Color	Hardness	Casing Diameter		Weight		Hole Diameter							
SAND		0	84	BROWN	SOFT	4 in. To 80 ft.		lbs./ft.		6.7 in. To 84 ft.							
Open Hole										From	ft.	To	ft.				
Screen? ☒		Type stainless		Make JOHNSON		Diameter		Slot/Gauze	Length	Set							
3 in.		12		4 ft.		80 ft.		84 ft.									
Static Water Level										63 ft.	land surface	Measure	09/25/2025				
Pumping Level (below land surface)										80 ft.	2 hrs.	Pumping at	10	g.p.m.			
Wellhead Completion										Pitless adapter manufacturer		MONITOR		Model		SNAPPY4X1	
☐ Casing Protection										☒ 12 in. above grade							
☐ At-grade (Environmental Wells and Borings ONLY)																	
Grouting Information										Well Grouted?		☒ Yes	☐ No	☐ Not Specified			
Material		Amount		From		To											
other		5 Sacks		ft. 50		ft.											
Nearest Known Source of Contamination										35 feet		Northwes Direction		Septic tank/drain field		Type	
Well disinfected upon completion?										☒ Yes	☐ No						
Pump ☐ Not Installed										Date Installed		11/01/2025					
Manufacturer's name										GRUNDFOS							
Model Number		SQ		HP		0.75		Volt		230							
Length of drop pipe		70		ft		Capacity		10		g.p.		Typ		Submersible			
Abandoned										Does property have any not in use and not sealed well(s)?		☐ Yes		☒ No			
Variance										Was a variance granted from the MDH for this well?		☐ Yes		☒ No			
Miscellaneous										First Bedrock		Aquifer					
Last Strat				Depth to Bedrock		ft											
Located by										Minnesota Department of Health							
Locate Method										GPS SA Off (averaged) (15 meters)							
System		UTM - NAD83, Zone 15, Meters		X		345791		Y		5202455							
Unique Number Verification										Info/GPS from data		Input Date		01/06/2026			
Angled Drill Hole																	
Well Contractor										Doug's Water Wells		6217		TORKELSON, P			
Licensee Business										Lic. or Reg. No.		Name of Driller					
Minnesota Well Index Report					897214					Printed on 10/02/2026 HE-01205-15							