

897228

County Otter Tail
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 03/20/2026
Update Date 03/20/2026
Received Date 12/08/2025

Well Name DESIGNER	Township 137	Range 42	Dir W	Section 5	Subsection DCA	Well Depth 60 ft.	Depth Completed 60 ft.	Date Well Completed 11/19/2025
Elevation	Elev. Method					Drill Method Non-specified Rotary	Drill Fluid Bentonite	
Address						Use domestic	Status Active	
Contact 3250 47TH ST S FARGO ND 58104						Well Hydrofractured? Yes ☐ No ☒ From To		
Well 51263 GOSSLEE RD DETROIT LAKES MN 56501						Casing Type Single casing Joint		
Stratigraphy Information						Drive Shoe? Yes ☐ No ☐ Above/Below		
Geological Material		From	To (ft.)	Color	Hardness	Casing Diameter Weight Hole Diameter		
TOP SOIL		0	1	BLACK	SOFT	4 in. To 56 ft. 2 lbs./ft. 6.7 in. To 60 ft.		
SAND/ GRAVEL		1	37	BROWN	MEDIUM			
SANDY CLAY		37	50	GRAY	HARD			
SAND		50	60	GRAY	SOFT			
						Open Hole From ft. To ft.		
						Screen? ☒ Type stainless Make JOHNSON		
						Diameter Slot/Gauze Length Set		
						3 in. 10 4 ft. 56 ft. 60 ft.		
						Static Water Level		
						30 ft. land surface Measure 11/19/2025		
						Pumping Level (below land surface)		
						56 ft. 1 hrs. Pumping at 30 g.p.m.		
						Wellhead Completion		
						Pitless adapter manufacturer Model		
						☐ Casing Protection ☒ 12 in. above grade		
						☐ At-grade (Environmental Wells and Borings ONLY)		
						Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified		
						Material Amount From To		
						other 3 Sacks ft. 46 ft.		
						Nearest Known Source of Contamination		
						85 feet East Direction Septic tank/drain field Type		
						Well disinfected upon completion? ☒ Yes ☐ No		
						Pump ☒ Not Installed Date Installed		
						Manufacturer's name		
						Model Number HP Volt		
						Length of drop pipe ft Capacity g.p. Typ		
						Abandoned		
						Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No		
						Variance		
						Was a variance granted from the MDH for this well? ☐ Yes ☒ No		
						Miscellaneous		
						First Bedrock Aquifer		
						Last Strat Depth to Bedrock ft		
						Located by		
						Locate Method		
						System UTM - NAD83, Zone 15, Meters X Y		
						Unique Number Verification Input Date		
						Angled Drill Hole		
						Well Contractor		
						Doug's Water Wells 6217 WESA, D		
						Licensee Business Lic. or Reg. No. Name of Driller		