

897231

County Clay
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date
Update Date 02/09/2026
Received Date 12/08/2025

Well Name RCH	Township 137	Range 44	Dir W	Section 17	Subsection ACA
Elevation	Elev. Method				
Address					
Contact 2343 10 UH DETROIT LAKES MN 56549					
Well 14345 260TH ST S HAWLEY MN 56549					
Stratigraphy Information					
Geological Material		From	To (ft.)	Color	Hardness
TOPSOIL		0	1	BLACK	SOFT
SANDY CLAY		1	82	BROWN	MEDIUM
SANDY CLAY		82	96	GRAY	SOFT
CLAY		96	202	GRAY	HARD
SAND		202	214	GRAY	SOFT
Well Depth 214 ft.					
Depth Completed 214 ft.					
Date Well Completed 11/19/2025					
Drill Method Non-specified Rotary		Drill Fluid Bentonite			
Use domestic					Status Active
Well Hydrofractured? Yes ☐ No ☒ From To					
Casing Type Single casing Joint					
Drive Shoe? Yes ☐ No ☐ Above/Below					
Casing Diameter 4 in. To		Weight 206 ft. 2 lbs./ft.		Hole Diameter 6.7 in. To 214 ft.	
Open Hole From ft. To ft.					
Screen? ☒ Type stainless Make JOHNSON					
Diameter		Slot/Gauze		Length Set	
8 in.		10		8 ft. 206 ft. 214 ft.	
Static Water Level 92 ft. land surface Measure 11/19/2025					
Pumping Level (below land surface) 206 ft. 1 hrs. Pumping at 20 g.p.m.					
Wellhead Completion Pitless adapter manufacturer Model					
☐ Casing Protection ☒ 12 in. above grade					
☐ At-grade (Environmental Wells and Borings ONLY)					
Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified					
Material		Amount		From To	
other		3.5 Sacks		ft. 50 ft.	
Nearest Known Source of Contamination 90 feet South Direction Septic tank/drain field Type					
Well disinfected upon completion? ☒ Yes ☐ No					
Pump ☒ Not Installed Date Installed					
Manufacturer's name					
Model Number		HP		Volt	
Length of drop pipe		ft Capacity		g.p. Typ	
Abandoned Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No					
Variance Was a variance granted from the MDH for this well? ☐ Yes ☒ No					
Miscellaneous First Bedrock Aquifer					
Last Strat		Depth to Bedrock		ft	
Located by					
Locate Method					
System		UTM - NAD83, Zone 15, Meters		X Y	
Unique Number Verification		Input Date			
Angled Drill Hole					
Well Contractor Doug's Water Wells 6217 ALSLEBEN, Z					
Licensee Business		Lic. or Reg. No.		Name of Driller	
Remarks					