

898451

County Stearns
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date
Update Date 05/05/2026
Received Date 02/02/2026

Well Name BOYER,	Township 123	Range 31	Dir W	Section 33	Subsection ADD	Well Depth 60 ft.	Depth Completed 60 ft.	Date Well Completed 11/12/2025
Elevation	Elev. Method					Drill Method Non-specified Rotary	Drill Fluid Bentonite	
Address						Use domestic	Status Active	
Contact 10414 106TH ST S PAPILLION NE 68046						Well Hydrofractured? Yes ☐ No ☐ From To		
Well 20547 EDGETON CT RICHMOND MN 56368						Casing Type Single casing Joint		
Stratigraphy Information						Drive Shoe? Yes ☐ No ☐ Above/Below		
Geological Material		From	To (ft.)	Color	Hardness	Casing Diameter Weight Hole Diameter		
SAND & CLAY		0	16	BROWN	SOFT	4 in. To 55 ft. lbs./ft. 7.9 in. To 60 ft.		
GRAEVL		16	23	GRAY	MEDIUM			
CLAY		23	50	GRAY	MEDIUM			
SAND		50	60	GRAY	SOFT			
						Open Hole From ft. To ft.		
						Screen? ☒ Type plastic Make		
						Diameter Slot/Gauze Length Set		
						4 in. 12 5 ft. 55 ft. 60 ft.		
						Static Water Level		
						6 ft. land surface Measure 11/12/2025		
						Pumping Level (below land surface)		
						40 ft. 2 hrs. Pumping at 50 g.p.m.		
						Wellhead Completion		
						Pitless adapter manufacturer Model		
						☐ Casing Protection ☒ 12 in. above grade		
						☐ At-grade (Environmental Wells and Borings ONLY)		
						Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified		
						Material Amount From To		
						other ft. 50 ft.		
						Nearest Known Source of Contamination		
						100 feet North Direction Septic tank/drain field Type		
						Well disinfected upon completion? ☒ Yes ☐ No		
						Pump ☐ Not Installed Date Installed		
						Manufacturer's name		
						Model Number HP Volt		
						Length of drop pipe ft Capacity g.p. Typ		
						Abandoned		
						Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No		
						Variance		
						Was a variance granted from the MDH for this well? ☐ Yes ☒ No		
						Miscellaneous		
						First Bedrock Aquifer		
						Last Strat Depth to Bedrock ft		
						Located by		
						Locate Method		
						System UTM - NAD83, Zone 15, Meters X Y		
						Unique Number Verification Input Date		
						Angled Drill Hole		
						Well Contractor		
						Albany Wells, Inc. 1650 ATKINSON, T.		
						Licensee Business Lic. or Reg. No. Name of Driller		